

## **4.05 Protection of Standpipe Inlets (2019)**

**Reference:** 2019 San Francisco Fire Code § 912 & 2016 NFPA 14 § 12.9

The San Francisco Fire Department requirements for the protection of standpipe inlet threads are as follows:

- I. Hose connections for standpipes shall be equipped with an approved plastic or metal plug which may be removed and reused.
- II. Unthreaded caps shall not be used.