

<b>Property Information</b>			<b>Contractor or Licensed Owner Information</b>			
Building Name			Name			
Address			Address			
City			License #	City	St.	Zip
Contact Person			<input type="checkbox"/> SFM	Phone		
Phone			<input type="checkbox"/> CSLB	Job #		
			Misc.			

Type of Standpipe System		Class of Standpipe System
<input type="checkbox"/> Manual Wet	<input type="checkbox"/> Automatic Dry	<input type="checkbox"/> Class I
<input type="checkbox"/> Manual Dry	<input type="checkbox"/> Semi-Automatic Dry	<input type="checkbox"/> Class II
<input type="checkbox"/> Automatic Wet	<input type="checkbox"/> Combined Sprinkler/Standpipe	<input type="checkbox"/> Class III

Riser Information				Main Drain Test (ANNUAL)			
Riser No.	Location	Riser Diameter	Main Drain Diameter	Initial Static Pressure	Residual Pressure	Final Static Pressure	P, F, N/A

This building has more than 5 risers. See additional AES 2.9 form attached      Number of AES 2.9 forms attached

5-Year Inspection, Testing and Maintenance						
<i>Includes ALL Quarterly and Annual Inspections, Tests, and Maintenance items</i>						
I = Inspection    T = Test    M = Maintenance				P = Pass    F = Fail    N/A = Not Applicable		
Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P, F, N/A
1.1	I	Control Valves – Identification Sign	13.3.1			
1.2	I	Control Valves – Inspection	13.3.2			
1.3	I	Waterflow Alarm Devices	5.2.5			
1.4	I	Supervisory Alarm Devices	5.2.5			
1.5	I	Pressure Gauges <i>Pass = Normal Pressures</i>	6.2.1 6.2.2			
1.6	I	Water Supply Pressure Below Dry pipe or Preaction Valve	6.2.1 6.2.2			psi
1.7	I	Water Supply Pressure Above Dry pipe or Preaction Valve	6.2.1 6.2.2			psi
1.8	I	Pressure at Top of Standpipe Riser	6.2.1 6.2.2, 13.2.7			psi
1.9	I	Air/Nitrogen Pressure	6.2.1 6.2.2, 13.2.7			psi
1.10	I	Pressure at Discharge of Fire pPmp or Pressure Tank	6.2.1 6.2.2, 13.2.7			psi
1.11	I	Pressure Readings Acceptable	6.2.2 13.2.7			
1.12	I	Hydraulic Design Information Sign <i>(For hydraulically designed systems)</i>	6.2.3			
1.13	I	Heat Tape	5.2.7			

<b>Property Information</b>			<b>Contractor or Licensed Owner Information</b>	
Building Name			Name	
Address			Job #	
City				

**5-Year Inspection, Testing and Maintenance**  
*Includes ALL Quarterly and Annual Inspections, Tests, and Maintenance Items*

I = Inspection    T = Test    M = Maintenance		P = Pass    F = Fail    N/A = Not Applicable				
Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P,F,N/A
1.14	I	Standpipe Hose Valves	13.5.6.1			
1.15	I	Pressure Reducing Hose Valves	13.5.2.1			
1.16	I	Pressure Reducing Valves	13.5.1.1			
1.17	I	Fire Department Connections	13.7			
1.18	I	Backflow Preventers	13.6.1			
1.19	I	Buildings (Freeze Protection)	4.1.1.1		<b>Owner's Responsibility</b>	
1.20	I	Pipe and Fittings	6.2.1 Table 6.1.2			
1.21	I	Hangers	6.2.1			
1.22	I	Seismic Braces	6.2.1			
1.23	I	Hose Connection	6.2.1 Table 6.1.2			
1.24	I	Cabinet	6.2.1 Table 6.1.2			
1.25	I	Hose	6.2.1 Table 6.1.2			
1.26	I	Hose Storage Device	6.2.1 Table 6.1.2			
1.27	I	Hose Nozzle	6.2.1 Table 6.1.2			
2.1	T	Control Valve - Position	6.2.1 13.3.3.1			
2.2	T	Control Valve - Operation	6.2.1 13.3.3.2			
2.3	T	Supervisory Devices	13.3.3.5			
2.4	T	Waterflow Alarm Devices <b>90 sec max. Enter time</b>	5.3.3 13.2.6		sec.	
2.5	T	Main Drain Test <b>(Enter data on Page 1 of this form)</b>	13.2.5 13.3.3.4			
2.6	T	Standpipe Flow Test	6.3.1		<b>Provide results in table on 1st page.</b>	
2.7	T	Standpipe Hydrostatic Test	6.3.2			
2.8	T	Hose Rack Assembly Flow Test	13.5.3.2			
2.9	T	Backflow Preventer Assemblies	13.6.2			
2.10	T	Pressure Reducing Hose Valves	13.5.2.2			
2.11	T	Pressure Reducing Valves	13.5.3.2			
2.12	T	Pressure Gauges	6.3.4			



