



File No:	[REDACTED]
CCN:	UUKF
Issued:	4/26/2023
Revised:	4/26/2023

ERCES CERTIFICATE

THIS CERTIFIES that the ERCES Service Company is included by UL LLC in its Directory as qualified to use the UL Listing Mark in connection with the certificated ERCES System. This Certificate is the ERCES Service Company's representation that the ERCES System including all connecting wiring and equipment has been installed and will be maintained in compliance with requirements established by UL. Further, this Certificate does not apply in any way to the installation of any additional signaling systems, such as fire, smoke, waterflow, burglary, holdup, medical emergency, or otherwise, that may be connected, installed or referenced along with the Certificated ERCES System. This Certificate does not apply in any way to the communication channel between the protected property and any facility that monitors signals from the protected property XXXX (Insert FCC License Holder language) unless the use of a UL listed, or Classified Alarm Transport Company is specified on the Certificate.

LIMITATION OF LIABILITY: UL LLC makes no representations or warranties, express or implied, that the installed ERCES will in all cases prevent any loss by fire, smoke, communication, water damage, burglary, hold-up or otherwise, or that the ERCES will in all cases provide the protection for which it is installed or intended. By the ERCES Service Company providing this Certificate and the Protected Property acceptance of this Certificate, the ERCES Service Company and the Protected Property acknowledge and agree that UL does not assume or undertake to discharge any liability of the ERCES Service Company or any other party. UL is not an insurer and assumes no liability which may result directly or indirectly from inspection of the equipment, failure of the equipment, failure to conduct inspections, incorrect certification, nonconformity with requirements, failure to discover nonconformity with requirements, cancellation of the Certificate or withdrawal of the ERCES Service Company from inclusion in ULs Directory prior to the expiration date appearing on this Certificate.

OPERATIONAL REQUIREMENTS: The ERCES Service Company bears the responsibility for the correctness of the installation; maintenance of the system documentation; periodic system inspection and testing; maintaining and providing any necessary repairs. All operations and maintenance shall be conducted in the manner prescribed by the requisite UL Listing and applicable NFPA standard referenced. All required service is to be provided for in an appropriate contract. System documentation is defined to include any "As Built Drawings"; the records of any "Acceptance Testing"; the records of all periodic system testing and maintenance and the issuance of documentation/letter from the FCC License Holder for Broadcast/Rebroadcast in accordance with local, state federal (inclusive of FCC) requirements.

SYSTEM DESCRIPTION

This system is installed and operated in accordance with:

Model Code: CFC 2019
 NFPA Standard: NFPA 1221 - 2019
 UL Listed (2524): Yes
 ETL/SGS/Other NRTL Listed (UL 2524): Yes
 Area Covered: Entire Building
 Authority Having Jurisdiction: San Francisco Fire Department
 Responding Fire Department: San Francisco Fire Department
 FCC License Holder: City and County of San Francisco

SYSTEM DEVIATIONS FROM REFERENCED NFPA STANDARDS

NONE

Protected Property:

[REDACTED]
 San Francisco, CA 94109 UNITED STATES

ERCES Company:

[REDACTED]

SN: [REDACTED].230426