

4.24 Fire Department Connections (FDC) Requirements (2016)

Reference: 2016 NFPA 13, Section 8.17.2; 2013 NFPA 14 Sections 4.8 and 6.4.5.4

Purpose: The San Francisco Fire Department may require more than one FDC in buildings when any of the following conditions exist:

1. The building fronts on more than one public way.
2. The building has significant floor area where firefighter response to the location of the fire may be delayed.
3. When the adjacent streets or public way characteristics may hinder firefighting operations.
4. When determined necessary by the Fire Department.

FDC location(s) shall be approved by Fire Department.