

## 4.17 Pre-Action Sprinkler System Supplied by Wet Pipe Sprinkler Systems (2025)

**Reference:** 2025 NFPA 13 Section 16.11.3.4 and 2025 Edition of the Automatic Sprinkler Systems Handbook.

### I. GENERAL REQUIREMENTS

1. **Non-Paddle-Type Water Flow Alarm Indicator.** When a wet pipe sprinkler system is the water supply source for a pre-action system, the wet pipe sprinkler system shall be provided with a non-paddle-type (alarm check valve) water-flow alarm indicator.

**Exception:** If this is not possible, the pre-action system must be supplied with water from a connection to a riser or a wet or combination standpipe, upstream of the paddle-type water-flow alarms indicator.

2. **High-Rise Buildings.** For buildings having floors used for human occupancy located more than 75 feet above the lowest level of fire department vehicle access (high rise buildings), the pre-action system shall be supplied, in the manner described above, with water from at least two risers or standpipes.

DRAFT