

## 4.26 Labels for Sprinkler System Control Valves (2025)

Reference: 2025 NFPA 13 Section 16.9.3.5

### I. GENERAL REQUIREMENTS

1. **Control Valve Identification.** All sprinkler and standpipe control valves shall be provided with identification signs at each valve to indicate its function and what it controls.
2. **Permanent Label/Tag To Identify Pressures.** Also, sprinkler control valves, including pressure regulating control valves (PRV's), shall be provided with a permanent label/tag that identifies the static pressure and residual pressure at a particular flow that is available at the valve outlet.

**Note:** All field adjustable pressure regulation valves (PRVs) for sprinkler systems and standpipes, including fire pump suction and discharge PRVs, must have a permanent tag that indicates the setting/pressure setting (i.e.; for standpipe fire hose valves it would be the setting in inches of water and for fire pump PRVs it is the pressure setting).

DRAFT